

State of Ohio En
North



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 11, 2008

RE: WAYNE COUNTY
AMERICAN LEGION POST 68
TRANSIENT PWS
PWS ID #OH8557812

CERTIFIED MAIL

American Legion Post No.68
1901 Sylvan Road
P.O. Box 162
Wooster, OH 44691

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

During November 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.

AMERICAN LEGION POST NO. 68
FEBRUARY 11, 2008
PAGE 2

If you have any questions, please contact Beth R. Madis at (330) 963-1194.

Sincerely,

A handwritten signature in black ink that reads "Nancy Rice" with a stylized flourish at the end.

Nancy W. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:bo

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW