



State of Ohio Environ
Northeast I



* 0 H 8 5 0 2 8 1 2 8 7 2 6 4 0 9 *

TELE: (330) 963-1200
www.epa...

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

2110 East Aurora Rd.
Twinsburg, Ohio 44087

NOTICE OF VIOLATION – ACTION REQUIRED

October 6, 2008

RE: WAYNE COUNTY
PEACH GROVE MOBILE HOME PARK
COMMUNITY WATER SYSTEM
PWS ID: OH8502812

Peach Grove Mobile Home Park
5704 Sunland St NE
Louisville, OH 44641

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During September 2008**

Dear Sir or Madam:

Peach Grove Mobile Home Park is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

- 1. Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
- 2. Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

Public Community
<ul style="list-style-type: none"> • Mail or other direct delivery to each customer; • If necessary to reach all persons regularly served, use other notification methods also, such as newspaper publication, public posting or Internet posting.
<p>Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.</p>

- 3. Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - Northeast District Office. Include a copy of each notice distributed, published or posted.

PEACH GROVE MOBILE HOME PARK
OCTOBER 6, 2008
PAGE 2

4. Monitor with at least five (5) routine samples in the month (October 2008) following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact me at 330-963-1194.

Sincerely,



Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

cc: Wayne County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW
Information Management Section, DDAGW, CO