



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 28, 2007

RE: ASHTABULA COUNTY
TREASURE ISLAND
TRANSIENT NON-COMMUNITY
PWS # 441712

Treasure Island
1898 West 25th Street
Cleveland, OH 44113

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in February 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in March 2007.

TREASURE ISLAND
FEBRUARY 28, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1236.

Sincerely,

A handwritten signature in black ink, appearing to read "David J. Bowland". The signature is written in a cursive style with a large, prominent initial "D".

David J. Bowland
Environmental Specialist
Division of Drinking and Ground Waters

DJB/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Ashtabula County Health Department
Kim Eppers, Ohio EPA, NEDO, DDAGW