



State of Ohio Environ

Northeast I



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 24, 2007

RE: CARROLL COUNTY
ATWOOD LAKE PARK - CAMPGROUND
TRANSIENT PUBLIC WATER SYSTEM
PWS ID: 1038411
STU ID: 1053122

Mr. Jim Rozelle, Interim Chief Engineer
Muskingum Watershed Conservancy District
1319 Third Street
P.O. Box 349
New Philadelphia, OH 44663

Dear Mr. Rozelle:

Atwood Lake Park - Campground is in violation of Ohio Revised Code Chapter 6109 by failing to comply with the requirements for filtration and disinfection of surface water systems pursuant to Ohio Administrative Code (OAC) rules 3745-81-71 through 3745-81-75, or 3745-83-01(B)(2).

Atwood Lake Park - Campground is in violation of OAC 3745-81-74 when the following monitoring requirements were not met during the month of July 2007.

The public water system failed to monitor for turbidity either continuously or every four hours that the water treatment plant was in operation on July 3rd, 10th, 16th, 21st, 26th, 27th.

The Atwood Lake Park - Campground is required by OAC 3745-81-32(D)(1)(a) to notify persons served by its water system of its failure to perform the monitoring that is established by OAC Chapter 3745-81.

The Atwood Lake Park - Campground non-community water system shall give notice within thirty days of the violation by hand delivery or continuous posting in conspicuous places throughout the area served by the water system. If the public notice is posted, the notice shall remain in place for no less than seven days.


If public notification has not yet been issued for the violation, the public water system may use the enclosed example public notice to notify persons served by its water system. The public water system must send a copy of the actual public notice used and the verification form to this district office within ten days after it has issued the notice.

ATWOOD LAKE PARK - CAMPGROUND
AUGUST 24, 2007
PAGE 2

If the public water system fails to correct its violations, then the Director may enforce the safe drinking water rules to attain compliance. An enforcement action may include civil penalties of not more than \$25,000 per day per violation in accordance with ORC §§6109.33 or administrative penalties in accordance with OAC 3745-81-04.

If you have any questions, please call me at (330) 963-1173.

Sincerely,



David L. Maschak
Environmental Specialist
Division of Drinking and Ground Waters

DLM:dms

enclosures: Example Public Notice
Verification Form

pc: Carroll County Health Department
IMS/DDAGW, CO
Kim Rhoads, Legal, CO
Kenneth Baughman, DDAGW-CMCU
Kim Ethers, DDAGW, NEDO, Violation Type 36, Contaminant ID 0200
James J. Pringle, Attorney-At-Law
Mark Jukich, Manager of Operations - MWCD
Bill Newsome, President, H2O Technologies
Brian Bisson, Aqua Ohio, Inc.