



State of Ohio Environm
Northeast D



* 0 H 1 5 0 1 5 1 2 8 7 3 2 3 0 7 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Lee Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 20, 2007

RE: COLUMBIANA COUNTY
VILLAGE OF LISBON
COMMUNITY WATER SYSTEM
PWS ID # 1501512
STU ID # 1553405

The Honorable Michael Lewis
Mayor, Village of Lisbon
203 North Market St.
Lisbon, OH 44432

Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.

Dear Mayor Lewis:

The Village of Lisbon is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the month of **February 2007**, because your water system uses a surface water source and does not provide adequate treatment. The Village of Lisbon will continue to be in violation of OAC Rule 3745-81-73 until modifications are made to the water system that would enable Ohio EPA to designate your source as ground water or until you install surface water treatment that meets the requirements of OAC Rules 3745-81-71 through 3745-81-74.

You are required by OAC Rule 3745-81-32 to issue a public notice of this violation. The Village must place the enclosed notice in every bi-monthly billing sent to customers until compliance is attained November 1, 2007. In addition, the enclosed notice must be published for one day in the local newspaper every three months until compliance is attained. I have enclosed an example public notice, which includes language that you must use in the notice, and a public notice verification form. **You must return a copy of the public notice that you issue along with the verification form to this office by April 10, 2007.**

If you have any questions, please contact me at the Northeast District Office at (330) 963-1248.

Respectfully

J. Robert Henn, Environmental Specialist
Division of Drinking and Ground Waters

enclosures

- cc: Columbiana County Health Department
- Toni Buchanan, Ohio EPA, Central Office, DDAGW
- Beth Messer, Ohio EPA, Central Office, DDAGW
- Nancy Glenny, Ohio EPA, NEDO, DDAGW - **Violation Code 41 SWTR - TT**
- Mike Ours, Village of Lisbon
- Scott Washam, Solicitor, Village of Lisbon, The Okey Law Firm, O.P.A.
- William Coleman, Board of Public Affairs, Village of Lisbon

JRH/ams