



State of Ohio Environmental  
 Northeast District

OH1501512 LISBON VILLAGE

41 08/30/07



\* 0 H 1 5 0 1 5 1 2 8 7 3 3 1 0 7 \*

2110 East Aurora Rd.  
 Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
 www.epa.state.oh.us

Ted Strickland, Governor  
 Lee Fisher, Lieutenant Governor  
 Chris Korleski, Director

August 28, 2007

RE: COLUMBIANA COUNTY  
 VILLAGE OF LISBON  
 COMMUNITY WATER SYSTEM  
 PWS ID # OH1501512; STU ID # 1553405

The Honorable Michael Lewis  
 Mayor, Village of Lisbon  
 203 North Market St.  
 Lisbon, OH 44432

**Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.**

Dear Mayor Lewis:

The Village of Lisbon is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the months of **July 2007**, because your water system uses a surface water source and does not provide adequate treatment. The Village of Lisbon will continue to be in violation of OAC Rule 3745-81-73 until modifications are made to the water system that would enable Ohio EPA to designate your source as ground water or until you install surface water treatment that meets the requirements of OAC Rules 3745-81-71 through 3745-81-74.

You are required by OAC Rule 3745-81-32 to issue a public notice of this violation. The Village must place the enclosed notice in every bi-monthly billing sent to customers until compliance is attained November 1, 2007. In addition, the enclosed notice must be published for one day in the local newspaper every three months until compliance is attained. I have enclosed an example public notice, which includes language that you must use in the notice, and a public notice verification form. **You must return a copy of the public notices that you issue along with the verification form to this office by September 14, 2007**

If you have any questions, please contact me at the Northeast District Office at (330) 963-1248.

Respectfully,

J. Robert Henn, Environmental Specialist  
 Division of Drinking and Ground Waters

JRH/ams

enclosures

cc: Columbiana County Health Department  
 Toni Buchanan, Ohio EPA, Central Office, DDAGW  
 Beth Messer, Ohio EPA, Central Office, DDAGW  
 Nancy Glenny, Ohio EPA, NEDO, DDAGW - **Violation Code 41 SWTR - TT**  
 Mike Ours, Village of Lisbon  
 Scott Washam, Solicitor, Village of Lisbon, The Okey Law Firm, O.P.A.