



State of Ohio Environ  
Northeast I

OH1542312 THIRD GENERATION

23 07/18/07 A



\* 0 H 1 5 4 2 3 1 2 9 6 5 2 7 0 7 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 18, 2007

RE: COLUMBIANA COUNTY  
THIRD GENERATION  
TRANSIENT PWS  
PWS ID # OH1542312

Third Generation  
P.O. Box 92  
Kensington, OH 44427

**Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms**

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

|                                    |                              |
|------------------------------------|------------------------------|
| <b>Monitoring Period:</b>          | <b>April - June 2007</b>     |
| <b>Required Coliform Sampling:</b> | <b>One /Calendar Quarter</b> |
| <b>Sample Results Submitted:</b>   | <b>None</b>                  |

| <b>Actions required as a result of the above violation</b> |  |
|--|--|
| Step 1   | <p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> <li>Continuous posting, mail, or other direct delivery; and</li> <li>If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system.</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2   | <p>Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.</p>  |

If samples were taken, we have not received the results. Please forward a copy of the results to my attention. Late reporting is a reporting violation but if the sample was taken and a result obtained, you will not need to issue the attached public notice.


THIRD GENERATION

July 18, 2007

Page 2

If you have any questions, please contact me at (330) 963-1293.

Sincerely,



Cynthia M. Petretich  
Environmental Specialist  
Division of Drinking and Ground Waters

CMP/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Columbiana County Health Department  
Kim Eppers, Ohio EPA, NEDO, DDAGW