



State of Ohio Environme
Northeast Dis

OH1564012 STATE LINE TAVERN

22 07/24/07



* 0 H 1 5 6 4 0 1 2 9 6 5 4 4 0 7 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 24, 2007

RE: COLUMBIANA COUNTY
STATE LINE TAVERN
TRANSIENT PUBLIC WATER SYSTEM
PWS # OH1564012

State Line Tavern
P.O. Box 67
East Palestine, OH 44413

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Owner/Operator:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

| Actions required as a result of the above violation | |
|---|--|
| Step 1 | <p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA. |
| Step 4 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in August 2007. |

STATE LINE TAVERN
JULY 24, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1293.

Sincerely,

A handwritten signature in black ink, appearing to read 'Cynthia M. Petretich', with a long horizontal flourish extending to the right.

Cynthia M. Petretich
Environmental Specialist
Division of Drinking and Ground Waters

CMP/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Columbiana County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW