



State of Ohio Environn
Northeast D

OH2861812 RPR VILLAGE - G SECTION PWS

22 05/14/07



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

May 14, 2007

RE: GEAUGA COUNTY
RPR VILLAGE - G SECTION PWS
TRANSIENT, NON-COMMUNITY
PWS # OH2861812

RPR Village
17000 Main Market
P.O. Box 671
Parkman, OH 44080

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in May 2007.


A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in June 2007.

RPR VILLAGE - G SECTION PWS
MAY 14, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1282.

Sincerely,

A handwritten signature in cursive script that reads "Donn Meehl". The signature is written in black ink and is positioned to the left of the typed name.

Donn Meehl
Environmental Specialist
Division of Drinking and Ground Waters

DM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Geauga County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW