



State of Ohio Environmen

Northeast Dist



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 3, 2007

RE: GEAUGA COUNTY  
BP OIL-CHAGRIN FALLS 4017 PWS  
TRANSIENT  
PWS # OH2864212

BP Products North America Inc.  
Environmental Compliance  
P.O. Box 6038  
Artesia, CA 90702

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in September 2007.


A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

| Actions required as a result of the above violation |  |
|---|--|
| Step 1  | <p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2  | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.  |
| Step 3  | Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.   |
| Step 4  | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in October 2007.   |

BP OIL-CHAGRIN FALLS 4017  
OCTOBER 3, 2007  
PAGE 2

If you have any questions, please contact me at (330) 963-1282.

Sincerely,

A handwritten signature in black ink that reads "Donn Meehl". The signature is written in a cursive style with a large initial "D" and a long, sweeping underline.

Donn Meehl  
Environmental Specialist  
Division of Drinking and Ground Waters

DM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Geauga County Health Department  
Kim Ethers, Ohio EPA, NEDO, DDAGW