



State of Ohio Environmental  
Northeast District



\* 0 H 2 8 6 3 7 1 2 8 2 1 6 4 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 28, 2007

RE: GEAUGA COUNTY  
**E-CHECK - AUBURN ROAD**  
TRANSIENT  
PWS #OH2863712

Envirotest Systems  
2180 Pinnacle Pkwy  
Twinsburg, OH 44087

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in December 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.


<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

E-CHECK - AUBURN ROAD  
DECEMBER 28, 2007  
PAGE 2

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in January 2008.
--------	--

If you have any questions, please contact me at (330) 963-1282.

Sincerely,



Donn Meehl  
Environmental Specialist  
Division of Drinking and Ground Waters

DM:ds

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Geauga County Health Department  
Kim Ethers, Ohio EPA, NEDO, DDAGW