




State of Ohio Environment  
Northeast District

OH2865612 FOWLERS MILL GOLF CLUBHOUSE

22 12/06/07 A



\* 0 H 2 8 6 5 6 1 2 8 6 4 6 4 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 6, 2007

RE: GEAUGA COUNTY  
FOWLERS MILL GOLF CLUBHOUSE  
TRANSIENT  
PWS # OH2865612

Fowlers Mill Golf Clubhouse  
13095 Rockhaven Rd.  
Chesterland, OH 44026

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in December 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in January 2008.

FOWLERS MILL GOLF CLUBHOUSE  
DECEMBER 6, 2007  
PAGE 2

If you have any questions, please contact me at (330) 963-1282.

Sincerely,

A handwritten signature in black ink that reads "Donn Meehl". The signature is written in a cursive style with a large initial 'D'.

Donn Meehl  
Environmental Specialist  
Division of Drinking and Ground Waters

DM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Geauga County Health Department  
Kim Etters, Ohio EPA, NEDO, DDAGW