



State of Ohio Environment  
Northeast District

OH2833312 GUIDOS PIZZA/PLAZA PWS

25 08/06/07



\* 0 H 2 8 3 3 3 1 2 8 1 8 6 3 0 7 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 6, 2007

RE: GEAUGA COUNTY  
GUIDO'S PIZZA/PLAZA PWS  
TRANSIENT PWS  
PWS ID # OH2833312

Guido's Pizza  
12775 Chillicothe Rd.  
Chesterland, OH 44026

**CERTIFIED MAIL**

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)**

Dear Owner/Manager:

During **July 2007**, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.

GUIDO'S PIZZA/PLAZA PWS  
AUGUST 6, 2007  
PAGE 2

Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in <b>August 2007</b> .
--------	---

If you have any questions, please contact Donn Meehl at (330) 963-1282.

Sincerely,



Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Geauga County Health Department  
Kim Etters, Ohio EPA, NEDO, DDAGW