



Northeast Dist



* 0 H 3 8 4 4 8 1 2 8 6 5 8 7 0 7 *

Chris Korieski, Director

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 F
www.epa.stat

June 12, 2007

RE: HOLMES COUNTY
MILLERSBURG UNITED
METHODIST CHURCH
TRANSIENT
PWS # OH3844812

Millersburg United Methodist Church
5395 TR 336
Millersburg, OH 44654

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a monthly violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in June 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in July 2007.

MILLERSBURG UNITED METHODIST CHURCH
JUNE 12, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1289.

Sincerely,

A handwritten signature in black ink, appearing to read "Wayne S. Butala". The signature is written in a cursive style with a horizontal line underneath.

Wayne Butala
Environmental Engineer
Division of Drinking and Ground Waters

WB/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Holmes County Health Department
Kim Eppers, Ohio EPA, NEDO, DDAGW