Ohio
State of Ohio Environmen
Northeast Dist

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 19, 2007

RE: MAHONING COUNTY
CAMP STAMBAUGH BSA MAIN
TRANSIENT PWS
PWS ID # OH5033112

Boy Scouts of America
4930 Enterprise Dr. NW
Warren, OH 44481

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Dear Sir or Madam:

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	**July-September 2007**
Required Coliform Sampling:	**one /Calendar Quarter**
Sample Results Submitted:	**NONE**

Actions required as a result of the above violation	
Step 1	**Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods: 1. Continuous posting, mail, or other direct delivery; and 2. If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system. *The language in italic on the attached public notice is mandatory language and must be included as written.*
Step 2	Within ten (10) days of completing **Step 1** above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

If samples were taken, we have not received the results. Please forward a copy of the results to my attention. Late reporting is a reporting violation but if the sample was taken and a result obtained, you will not need to issue the attached public notice.

If you have any questions, please contact me at (330) 963-1121.

Sincerely,

Corey Kurjian
Environmental Specialist
Division of Drinking and Ground Waters

CK/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Mahoning County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW