



State of Ohio Enviro

Northeast



* 0 H 5 2 5 9 0 0 2 8 3 9 1 6 0 7 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 3, 2007

RE: MEDINA COUNTY
CHIPPEWA VALLEY CAMPGROUND
TRANSIENT WATER SYSTEM
PWS ID #OH5259002

CERTIFIED MAIL

Mr. William Carrasco
Mr. Orlando Carrasco
Chippewa Valley Campground & Soccer Facilities
8809 Lake Road
Seville, OH 44273

**Subject: Notice of Water Use Advisory &
Violation of Maximum Contaminant Level for Total Coliform Bacteria**

Dear Messrs. Carrasco:

We received the following total coliform sample results from your public water system. The bacteriological analysis is as follows:

Sample Date	Sample Tap	Total Coliform	E. Coli	Fecal Coliform	Sample Number	Lab Number
11/28/07	women's RR	Positive	Positive	N/A	72545	820
11/28/07	women's RR	Positive	Positive	N/A	72546	820
11/28/07	women's RR	Positive	Positive	N/A	72547	820
11/28/07	women's RR	Positive	Positive	N/A	72548	820
11/28/07	women's RR	Positive	Positive	N/A	72549	820

Your public water system incurred a monthly violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in November 2007. A monthly violation of rule 3745-81-14 occurs when more than one of your samples within the month are total coliform-positive.

In addition, due to the receipt of *E coli* positive results from your drinking water system for the last three consecutive months, a water use advisory shall be issued immediately for the protection of public health.

Actions required as a result of the above violation	
Step 1	<p>Within 24 hours of being notified of the total coliform positive sample results, collect four (4) repeat sample. All repeat samples must be collected on the same day. The four repeat samples must be taken from the following locations:</p> <ol style="list-style-type: none"> a. The same sampling tap as the original total coliform positive sample. b. A sampling tap within 5 sampling points upstream from the original tap. c. A sampling tap within 5 sampling points upstream from the original tap. d. Another sampling tap within 5 sampling points upstream or downstream from the original tap. <p>Note: If only one sample tap is available, four repeat samples should be collected from that tap at least five minutes apart while the water is left running. Alternatively, four repeat samples may be taken at 30 minute intervals.</p>
Step 2	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> 1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 3	<p>Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.</p>
Step 4	<p>Within ten (10) days of completing Step 2 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.</p>

Step 5	Lifting the Advisory - The public notice water use advisory shall remain in effect until the investigation has revealed the problem, specific corrective steps have been taken, following which you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample." It is advisable to notify your customers when the problem is corrected.
Step 6	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in December 2007.

If you have any questions, please contact at (330) 963-1195.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:dms

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Medina County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW