



State of Ohio Enviro  
Northeast



\* 0 H 5 2 5 8 4 1 2 8 3 9 1 1 0 8 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

December 10, 2007

RE: MEDINA COUNTY  
**SPEEDWAY 3650 PWS**  
TRANSIENT  
PWS #OH5258412

Speedway Super America LLC  
Attn: Environmental Compliance  
P.O. Box 1500  
Springfield, OH 45501

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in December 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.


| <b>Actions required as a result of the above violation</b> |  |
|--|--|
| Step 1   | <p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2   | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.  |
| Step 3   | Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.   |

SPEEDWAY 3650  
DECEMBER 10, 2007  
PAGE 2

|        |  |
|--------|--|
| Step 4 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in January 2007. |
|--------|--|

If you have any questions, please contact me at (330) 963-1235.

Sincerely,



Leslie A. Otten  
Environmental Specialist  
Division of Drinking and Ground Waters

LAO:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Medina County Health Department  
Kim Eppers, Ohio EPA, NEDO, DDAGW