



State of Ohio Envir  
Northeast



TELE: (330) 963-... \* 0 H 5 2 5 9 0 0 2 8 3 9 1 7 0 7 \*  
www.epa.state.oh.us

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 10, 2007

RE: MEDINA COUNTY  
CHIPPEWA VALLEY CAMPGROUND PWS  
TRANSIENT WATER SYSTEM  
PWS ID #OH5259002

**CERTIFIED MAIL**

Chippewa Valley Campground  
8809 Lake Road  
Seville, OH 44273

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE - E. coli positive and a Monthly)**

Dear Sir/Madam:

Your public water system incurred an **acute** and **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.

An acute violation occurs when:

- a repeat sample is either fecal or E. coli-positive; or
- a repeat sample is total coliform-positive following a fecal or E. coli positive routine sample.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA <b>and</b> issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>

Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.
Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in November 2007.

If you have any questions, please contact Leslie A. Otten at (330) 963-1235.

Sincerely,



Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR:dms

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Medina County Health Department  
Kim Eppers, Ohio EPA, NEDO, DDAGW