



State of Ohio Envir
Northeast



* 0 H 5 2 3 8 6 1 2 8 6 7 7 0 0 7 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 467-0769
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 30, 2007

RE: MEDINA COUNTY
CLUB LAFAYETTE PWS
TRANSIENT WATER SYSTEM
PWS ID# 5238612

Owner
Club Lafayette
7511 Lafayette Road
Lodi, OH 44254

Dear Owner:

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	January - March 2007
Required Coliform Sampling:	One/Calendar Quarter
Sample Results Submitted:	None

Actions required as a result of the above violation

Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> Continuous posting, mail, or other direct delivery; and If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system. <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
--------	--


Step 2	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
--------	--

If samples were taken, we have not received the results. Please forward a copy of the results to my attention. Late reporting is a reporting violation, but if the sample was taken and a result obtained, you will not need to issue the attached public notice.

Please be advised that Club Lafayette has now been in violation for three consecutive monitoring quarters. Continued non-compliance with monitoring requirements will result in further enforcement action.

If you have any questions, please contact me at (330) 963-1235.

Sincerely,


Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Medina County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW