



Fik

State of Ohio Environme

OH6784912 SOUTHEAST MIDDLE SCHOOL PWS

52 11/06/07 A

Northeast Dis

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200
www.epa.st



November 6, 2007

RE: PORTAGE COUNTY
SOUTHEAST MIDDLE SCHOOL
NTNC WATER SYSTEM
PWS ID NO. 6784912

Mr. Fred Fries, Business Manager
Southeast Local Schools
8245 Tallmadge Road
Ravenna, OH 44266

Dear Mr. Fries:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least 10 appropriate sites for lead and copper analyses during the July - September 2007 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. Only 8 samples were collected from appropriate sites. Two of the samples were collected from locations that do not meet the requirements of the regulation, and were invalidated.

Please be advised that the following actions are required:

1. Collect a first draw sample from 10 appropriate taps for lead and copper during the July - September 2008 monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system.

An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.

If you have any questions, please feel free to contact me at this office at (330) 963-1235.

Sincerely,

Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

enclosures

cc: Ohio EPA, Central Office, DDAGW-IMS
Kim Eppers, NEDO, DDAGW