



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 16, 2007

RE: PORTAGE COUNTY  
CITY OF STREETSBORO  
COMMUNITY WATER SYSTEM  
PWS # 6705003

Mr. John Kuklisin  
City of Streetsboro  
2094 State Route 303  
Streetsboro, OH 44241

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Mr. Kuklisin:

The City of Streetsboro incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in August 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive. A routine sample from Step 2 was reported to be total coliform positive. The repeat sample from the same location was also positive; however, the surrounding locations were all negative. An investigation was conducted and all samples from within Step 2 were also negative. It has been determined that the routine sample location, an outside faucet, is no longer in use and the positive results are from that location only.

| <b>Actions required as a result of the above violation</b> |  |
|--|--|
| Step 1   | <p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |

CITY OF STREETSBORO  
AUGUST 16, 2007  
PAGE 2

|        |  |
|--------|--|
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.  |
| Step 3 | Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.         |
| Step 4 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in September 2007. |

If you have any questions, please contact me at (330) 963-1235.

Sincerely,



Leslie A. Otten  
Environmental Specialist  
Division of Drinking and Ground Waters

LAO:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Portage County Health Department  
Nancy Glenny, Ohio EPA, NEDO, DDAGW