



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 19, 2007

RE: PORTAGE COUNTY
GOODYEAR - AIRSHIP OPS.
NON-TRANSIENT PWS
PWS ID# OH6781912

Mr. Scott Babbo, Airship Base Sup't.
Goodyear Airship Operations
841 Wingfoot Lake Rd.
Mogadore, OH 44260

**SUBJECT: NOTICE OF VIOLATION - FAILURE TO SAMPLE DRINKING WATER
AS REQUIRED FOR TOTAL COLIFORMS**

Dear Mr. Babbo:

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements. Several special purpose bacteria samples were collected in October to determine where the bacteria is originating from. It appears that the bacteria is coming from the new treatment equipment recently installed and steps are being taken to correct this problem. Due to the ongoing investigation no routine samples were collected in October.

Monitoring Period:	October 2007
Required Coliform Sampling:	At least 5 routine samples in the month after a coliform-positive
Sample Results Submitted:	None

Actions required as a result of the above violation

Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> 1. Continuous posting, mail, or other direct delivery; and 2. If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system. <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
--------	--

GOODYEAR AIRSHIP OPS
NOVEMBER 19, 2007
PAGE 2

Step 2	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
--------	--

If samples were taken, we have not received the results. Please forward a copy of the results to my attention. Late reporting is a reporting violation but if the sample was taken and a result obtained, you will not need to issue the attached public notice.

If you have any questions, please contact me at (330) 963-1235.

Sincerely,



Leslie Otten
Environmental Specialist
Division of Drinking and Ground Waters

LO:ds

enclosures

cc: Mr. Greg Stallings, Envir. Eng., Goodyear Tire & Rubber Co.,
Toni Buchanan, Ohio EPA, Central Office, DDAGW
Portage County Health Department
Nancy Glenn, Ohio EPA, NEDO, DDAGW