



State of Ohio Envir

Northeast



\* 0 H 7 6 6 2 3 1 2 5 9 8 1 3 0 7 \*

2110 East Aurora Road  
Twinsburg, OH 44087-1924

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Laura H. Powell, Acting Director

January 18, 2007

RE: STARK COUNTY  
BYLER'S FLEA MARKET PWS  
TRANSIENT NON-COMMUNITY  
PWS #7662312

Byler's Flea Market  
960 Edison Street  
Hartville, OH 44632

**Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria**

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of Rule 3745-81-14 of the Ohio Administrative Code (OAC) in January 2007.

A monthly violation of Rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.


<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

BYLER'S FLEA MARKET  
JANUARY 18, 2007  
PAGE 2

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in February 2007.
--------	---

If you have any questions, please contact me at (330) 963-1269.

Sincerely,



Mandy Razzano  
Environmental Specialist  
Division of Drinking and Ground Waters

MLR:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Stark County Health Department  
Kim Etters, Ohio EPA, NEDO, DDAGW