Ohio
State of Ohio Environmen
Northeast Dis

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 31, 2007

RE: STARK COUNTY
MCDONALDS RESTAURANT HARTVILLE
TRANSIENT WATER SYSTEM
PWS ID #OH7655012

Tomtreyco
5221 West Blvd. NW
Canton, OH 44718

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE - E. Coli positive and a Monthly)**

Dear Sir/Madam:

Your public water system incurred an **acute** and **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

An acute violation occurs when:

- a repeat sample is either fecal or E. coli-positive; or
- a repeat sample is total coliform-positive following a fecal or E. coli positive routine sample.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

| **Actions required as a result of the above violation** | |
|---|---|
| Step 1 | **Within 24 hours,** consult with Ohio EPA **and** issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:<br><br>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)<br><br>*The language in italic on the attached public notice is mandatory language and must be included as written.* |

| | |
|---|---|
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Within ten (10) days of completing **Step 1** above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA. |
| Step 4 | Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample." It is advisable to notify your customers when the problem is corrected. |
| Step 5 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in August 2007. |

If you have any questions, please contact Mandy Razzano at (330) 963-1269.

Sincerely,

Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:dms

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Stark County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW