State of Ohio Environmei
Northeast Dis

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 9, 2007

RE: STARK COUNTY
ARMY NAVY GARRISON 2003 PWS
TRANSIENT
PWS #OH7674012

Stump Hill Farm
6633 Klick Street SW
Massillon, OH 44646

Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	**Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: 1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) *The language in italic on the attached public notice is mandatory language and must be included as written.*
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing **Step 1** above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in November 2007.

If you have any questions, please contact me at (330) 963-1269.

Sincerely,

Mandy Razzano

Mandy Razzano
Environmental Specialist
Division of Drinking and Ground Waters

MLR:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Stark County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW