



Northeast District

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200  
www.epa.state.oh.us



Chris Korleski, Director

February 6, 2007

RE: STARK COUNTY  
MILLER WELD MASTER PWS  
NON-TRANSIENT NON-COMMUNITY  
PWS #7675112

Miller Weld Master  
4220 Alabama Avenue  
Navarre, OH 44662

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in January 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>

MILLER WELD MASTER  
FEBRUARY 6, 2007  
PAGE 2

Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in February 2007.

If you have any questions, please contact me at (330) 963-1236.

Sincerely,



David J. Bowland  
Environmental Specialist  
Division of Drinking and Ground Waters

DJB:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Stark County Health Department  
Nancy Glenny, Ohio EPA, NEDO, DDAGW