State of Ohio En
North
2110 East Aurora Rd.
Twinsburg, Ohio 44087
TELE: (330) 9
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

OH7673212 REGAL METAL PRODUCTS CO PWS 25 06/15/07 I

May 16, 2007

RE: STARK COUNTY
REGAL METAL PRODUCTS CO. PWS
NON-TRANSIENT PWS
PWS ID # OH7673212

Regal Metal Products Co.
3615 Union Avenue SE
P.O Box 207
Minerva, OH 44657

CERTIFIED MAIL

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

Dear Owner/Operator:

During April 2007, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	**Within 24 hours,** consult with Ohio EPA **and** issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system: 1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) *The language in italic on the attached public notice is mandatory language and must be included as written.*
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.

Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in May 2007.

If you have any questions, please contact David J. Bowland at (330) 963-1236.

Sincerely,

Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

Enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Stark County Health Department
Nancy Glenny, Ohio EPA, NEDO, DDAGW