



State of Ohio Environ  
Northeast I

OH7674412 DEVILLE APARTMENTS

51 02/22/07



\* 0 H 7 6 7 4 4 1 2 8 4 7 9 0 7 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-120.  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 22, 2007

RE: STARK COUNTY  
DEVILLE APARTMENTS  
COMMUNITY WATER SYSTEM  
PWS ID NO. 7674412

Mr. Donald DeVille, President and CEO  
DeVill Apartments and Builders, Inc.  
4811 Whipple Ave. N.W., Suite 101  
Canton, OH 44718

Dear Mr. DeVille:

This letter is notification that your water system is in violation of Chapter 3745-81-86 of the Ohio Administrative Code (OAC) for failure to comply with lead and copper tap monitoring requirements.

These regulations required that your water system collect a first draw sample from at least five appropriate sites for lead and copper analyses during the July-December 2006 monitoring period. Ohio EPA records indicate that your water system failed to conduct this required monitoring. This failure to monitor for lead and copper at consumer's taps is a violation of the aforementioned regulation and could subject your water system to enforcement action.

Please be advised that the following actions are required:

1. Collect a first draw sample from five appropriate taps for lead and copper during the January-June 2007 monitoring period.
2. Issue public notification for your violation within 30 days by mail or hand delivery or by continuous posting in conspicuous places throughout the area served by the water system.

An example public notice is attached for your information. A copy of the public notification, along with the enclosed verification form, must be forwarded to this office within ten days following issuance of the public notification.

3. Comply with all parts of any U.S. EPA or Ohio EPA Administrative Order.

If you have any questions, please feel free to contact me at this office at (330) 963-1236.

Sincerely,

David J. Bowland  
Environmental Specialist  
Division of Drinking and Ground Waters

DJB:dms

enclosures

pc: IMS, DDAGW, CO  
Kim Etters, NEDO, DDAGW