



State of Ohio Environmental Protection Agency  
OH7646512 MEADOWLAKE GOLF AND SWIM

North



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 96  
ww

Jonathan, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 16, 2007

RE: STARK COUNTY  
MEADOWLAKE GOLF & SWIM  
TRANSIENT NON-COMMUNITY  
PWS ID # 7646512

Messrs. Roy E. Barr and Philip Barr  
dba Meadowlake Golf & Swim  
Meadowlake Corporation  
Meadowlake, Limited  
1211 39<sup>th</sup> Street NE  
Canton, OH 44714

**Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.**

Dear Messrs. Barr:

Your public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the months of April, May, and June, 2007, because your water system uses a source that has been designated as a surface water source, and you do not provide adequate treatment. You will continue to be in violation of OAC Rule 3745-81-73 until you make modifications to your water system that would enable Ohio EPA to designate your source as ground water or until you install surface water treatment that meets the requirements of OAC Rule 3745-81-71 thru 3745-81-74.

<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italics on the attached public notice is mandatory and must be included as written.</i></p>

MEADOWLAKE GOLF & SWIM  
AUGUST 16, 2007  
PAGE 2

Step 2	Initiate an Investigation and take the necessary steps to correct the problem as soon as possible.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.

If you have any questions, please contact me at (330) 963-1236.

Sincerely,



David J. Bowland  
Environmental Specialist  
Division of Drinking and Ground Waters

DJB:dms

enclosures

pc: Toni Buchanan, DDAGW, CO  
Stark County Health Department  
Kim Etters, DDAGW, NEDO