



State of Ohio Environ
Northeast I



* 0 H 7 6 4 6 5 1 2 9 7 6 4 4 0 7 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 28, 2007

RE: STARK COUNTY
MEADOWLAKE GOLF & SWIM
TRANSIENT NON-COMMUNITY
PWS ID # 7646512

Messrs. Roy E. Barr and Philip Barr
dba Meadowlake Golf & Swim
Meadowlake Corporation
Meadowlake, Limited
1211 39th Street NE
Canton, OH 44714

Subject: Notice of Violation - Failure to provide adequate treatment of a surface water source.

Dear Messrs. Barr:

Your public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-81-73 for the month of July, 2007, because your water system uses a source that has been designated as a surface water source, and you do not provide adequate treatment. You will continue to be in violation of OAC Rule 3745-81-73 until you make modifications to your water system that would enable Ohio EPA to designate your source as ground water or until you install surface water treatment that meets the requirements of OAC Rule 3745-81-71 thru 3745-81-74.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italics on the attached public notice is mandatory and must be included as written.</i></p>
Step 2	Initiate an Investigation and take the necessary steps to correct the problem as soon as possible.

MEADOWLAKE GOLF & SWIM
AUGUST 28, 2007
PAGE 2

Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
--------	---

If you have any questions, please contact me at (330) 963-1236.

Sincerely,



David J. Bowland
Environmental Specialist
Division of Drinking and Ground Waters

DJB:dms

enclosures

pc: Toni Buchanan, DDAGW, CO
Stark County Health Department
Kim Etters, DDAGW, NEDO