



State of Ohio Environm

OH7724512 GHENT CHRISTIAN CHURCH

25 06/27/07 A

Northeast Di



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200
www.epa.s

Gov. Jon H. ...
Chris Korleski, Director

December 18, 2007

RE: SUMMIT COUNTY
GHENT CHRISTIAN CHURCH
TRANSIENT PWS
PWS ID #OH7724512

CERTIFIED MAIL

Ghent Christian Church
4200 Granger Road
Akron, OH 44333-1418

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

Dear Sir/Madam:

During **December 2007**, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

| Actions required as a result of the above violation | |
|--|---|
| Step 1 | <p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA. |

GHENT CHRISTIAN CHURCH
DECEMBER 18, 2007
PAGE 2

| | |
|--------|--|
| Step 4 | Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected. |
| Step 5 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in January 2008 . |

If you have any questions, please contact Ursula Musselman at (330) 963-1227.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR:dms

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Summit County Health Department
Kim Eters, Ohio EPA, NEDO, DDAGW