



North



TELE: (330) 96

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

Lieutenant Governor  
Chris Korleski, Director

October 25, 2007

RE: SUMMIT COUNTY  
GIANT OIL STATION #432  
TRANSIENT  
PWS # OH7742712

Giant Oil, Inc.  
3904 Corporex Park Drive  
Suite 150  
Tampa, FL 33619

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

GIANT OIL STATION #432  
OCTOBER 25, 2007  
PAGE 2

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in November 2007.
--------	---

If you have any questions, please contact me at (330) 963-1227.

Sincerely,



Ursula Musselman  
Environmental Specialist  
Division of Drinking and Ground Waters

UM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Ed Wood, Barberton Health District  
Kim Ethers, Ohio EPA, NEDO, DDAGW