



State of Ohio Envir  
Northeas

OH7786612 MCAFEE TOOL AND DIE, INC

22 08/20/07

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1:  
www.e



Chris Korleski, Director

September 7, 2007

RE: SUMMIT COUNTY  
MCAFEE TOOL AND DIE, INC  
NON-TRANSIENT  
PWS #OH7786612

Mrs. Cathy Wallace  
McAfee Tool & Die, Inc.  
1717 Boettler Road  
Uniontown, OH 44685

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir/Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.

MCAFEE TOOL & DIE, INC.  
SEPTEMBER 7, 2007  
PAGE 2

Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in August 2007.
--------	---

If you have any questions, please contact me at (330) 963-1227.

Sincerely,



Ursula Musselman  
Environmental Specialist  
Division of Drinking and Ground Waters

UM:ds

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Summit County Health Department  
Nancy Glenny, Ohio EPA, NEDO, DDAGW