

State of Ohio Environ
Northeast



* 0 H 7 8 4 2 3 1 2 9 7 8 8 4 0 8 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-12
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 25, 2007

RE: TRUMBULL COUNTY
HARMONY HILL FAMILY
RESTAURANT & LOUNGE
TRANSIENT
PWS # OH7842312

Harmony Hill Family Restaurant & Lounge, Inc.
1300 Greenville Road
Cortland, OH 44410

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in October 2007.


A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in November 2007.

HARMONY HILL FAMILY RESTAURANT & LOUNGE
OCTOBER 25, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1242.

Sincerely,


Charlotte E. Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CEH/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Trumbull County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW