



State of Ohio Environ  
Northeast



\* 0 H 7 8 5 3 0 1 2 9 7 8 9 7 0 7 \*

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-12L  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 16, 2007

RE: TRUMBULL COUNTY  
DUCK CREEK GOLF COURSE  
TRANSIENT PWS  
PWS ID #OH7853012

**CERTIFIED MAIL**

Duck Creek Golf Course  
3351 Newton Falls-Tomlinson Road  
Warren, OH 44481

**Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)**

Dear Sir/Madam:

During **July 2007**, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.


<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 24 hours</b>, consult with Ohio EPA <b>and</b> issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <p>1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</p> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.

DUCK CREEK GOLF COURSE  
JULY 16, 2007  
PAGE 2

Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in <b>August 2007</b> .
--------	---

If you have any questions, please contact Charlotte E. Hammar at (330) 963-1242.

Sincerely,



Nancy N. Rice  
Environmental Manager  
Division of Drinking and Ground Waters

NNR:dms

enclosures

pc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Trumbull County Health Department  
Kim Ethers, Ohio EPA, NEDO, DDAGW