



State of Ohio Environ
Northeast



2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-120
www.epa.state.oh.us

Lee Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

April 17, 2007

Re: Trumbull County
Beacon of Hope Baptist Church
Transient PWS
PWS ID# OH7852912

Beacon of Hope Baptist Church
3559 North Park Ave.
Warren, OH 44483

Subject: Notice of Violation - Failure to Sample Drinking Water as Required for Total Coliforms

Dear Sir/Madam:

Your public water system is in violation of Rule 3745-81-21 of the Ohio Administrative Code for failure to comply with the coliform monitoring requirements:

Monitoring Period:	January - March, 2007
Required Coliform Sampling:	ONE/Calendar Quarter
Sample Results Submitted:	None


Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with Rule 3745-81-32 of the Ohio Administrative Code by the following methods:</p> <ol style="list-style-type: none"> Continuous posting, mail, or other direct delivery; and If necessary, the system must also use any other method reasonably calculated to reach all persons served by the public water system. <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>

Step 2	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
--------	--

If samples were taken, we have not received the results. Please forward a copy of the results to my attention. Late reporting is a reporting violation but if the sample was taken and a result obtained, you will not need to issue the attached public notice.

If you have any questions, please contact me at (330) 963-1242.

Sincerely,



Charlotte E. Hammar
Environmental Specialist
Division of Drinking and Ground Waters

CEH:dms

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Trumbull County Health Department
Kim Etters, Ohio EPA, NEDO, DDAGW