



State of Ohio Enviror
Northeast



* 0 H 8 5 5 0 7 1 2 7 1 8 1 8 0 8 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-126
www.epa.state.oh.us

Lee Fisher, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 17, 2007

RE: WAYNE COUNTY
WESTWOOD BAPTIST CHURCH
TRANSIENT
PWS # OH8550712

Westwood Baptist Church
969 Blachleyville Road
Wooster, OH 44691

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in **December 2007**.


A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	<p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in January 2008 .

WESTWOOD BAPTIST CHURCH
DECEMBER 17, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1194.

Sincerely,

A handwritten signature in black ink, appearing to read "Beth R. Madis". The signature is fluid and cursive, with a large initial "B" and "M".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Kim Eppers, Ohio EPA, NEDO, DDAGW