



State of Ohio Envir
Northeast

OH8532912 CAMP LUZ



TELE: (330) 963-1

www.epa.state.oh.us

2110 East Aurora Rd.
Twinsburg, Ohio 44087

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 25, 2007

RE: WAYNE COUNTY
CAMP LUZ, KITCHEN WELL
TRANSIENT WATER SYSTEM
PWS ID # OH8532912

Camp Luz
152 Kidron Rd.
Orrville, OH 44667

CERTIFIED MAIL

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE - E. coli positive and a Monthly)

Dear Sir or Madam:

Your public water system incurred an **acute** and **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in July 2007.

An acute violation occurs when:

- A repeat sample is either fecal or E. coli-positive; or
- A repeat sample is total coliform-positive following a fecal or E. coli positive routine sample.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

| Actions required as a result of the above violation | |
|--|---|
| Step 1 | <p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA. |

CAMP LUZ, KITCHEN WELL
JULY 25, 2007
PAGE 2

| | |
|--------|--|
| Step 4 | Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected. |
| Step 5 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in August 2007. |

If you have any questions, please contact Beth R. Madis at (330) 963-1194.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

Enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW