



State of Ohio Environme

Northeast Di



* 0 H 8 5 5 5 3 1 2 8 7 2 3 5 0 7 *

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 13, 2007

RE: WAYNE COUNTY
TOWN AND COUNTRY CAMPGROUND
TRANSIENT PWS
PWS ID # OH8555312

Mr. Rick Witucki
7555 Shilling Rd.
West Salem, OH 44287

CERTIFIED MAIL

Subject: Notice of Violation of Maximum Contaminant Level for Total Coliform Bacteria (ACUTE & Failure to Monitor with four repeat samples)

Dear Mr. Witucki:

During **June 2007**, your public water system incurred an **acute** violation of rule 3745-81-14 (D) of the Ohio Administrative Code (OAC) and a **monitoring** violation of rule 3745-81-21 (B)(1) of the OAC for failure to collect four (4) repeat samples within the required time period.

Actions required as a result of the above violation	
Step 1	<p>Within 24 hours, consult with Ohio EPA and issue the attached public notice in accordance with rule 3745-81-32 of the Ohio Administrative Code using the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Fill out the attached verification form and send along with a copy of the public notification issued within 10 days to the District Office of the Ohio EPA.
Step 4	Lifting the Advisory - The public notice water use advisory shall remain in effect until you obtain one complete set of four (4) total coliform-negative (contain no coliforms) repeat samples. Clearly mark each repeat sample slip as "repeat sample". It is advisable to notify your customers when the problem is corrected.

TOWN AND COUNTRY CAMPGROUND
JULY 13, 2007
PAGE 2

Step 5	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in July 2007 .
--------	---

If you have any questions, please contact Beth R. Madis at (330) 963-1194.

Sincerely,



Nancy N. Rice
Environmental Manager
Division of Drinking and Ground Waters

NNR/ams

Enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW