



State of Ohio E

Northe



TELE: (330) ... www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Laura H. Powell, Acting Director

2110 East Aurora Road
Twinsburg, OH 44087-1924

January 9, 2007

RE: WAYNE COUNTY
WESTWOOD BAPTIST CHURCH
TRANSIENT NON-COMMUNITY
PWS # 8550712

Westwood Baptist Church
969 Blachleyville Road
Wooster, OH 44691

**Subject: Notice of Violation of Monthly Maximum Contaminant Level
for Total Coliform Bacteria**

Dear Pastor:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in January 2007.


A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

| Actions required as a result of the above violation | |
|--|--|
| Step 1 | <p>Within 30 days issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p> |
| Step 2 | Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination. |
| Step 3 | Within ten (10) days of completing Step 1 above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA. |
| Step 4 | Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in February 2007. |

WESTWOOD BAPTIST CHURCH
JANUARY 9, 2007
PAGE 2

If you have any questions, please contact me at (330) 963-1194.

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Kim Ethers, Ohio EPA, NEDO, DDAGW