State of Ohio Environ
Northeast

2110 East Aurora Road
Twinsburg, OH 44087-1924

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Bob Taft, Governor
Bruce Johnson, Lieutenant Governor
Joseph P. Koncelik, Director

January 5, 2007

RE: WAYNE COUNTY
ADVANCED DRAINAGE SYSTEMS PWS
NON-TRANSIENT NON-COMMUNITY
PWS # 8561312

Advanced Drainage Systems
3113 Lincoln Way West
Wooster, OH 44691

Subject: Notice of Violation of Monthly Maximum Contaminant Level for Total Coliform Bacteria

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in January 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

Actions required as a result of the above violation	
Step 1	**Within 30 days** issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system: 1. Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.) *The language in italic on the attached public notice is mandatory language and must be included as written.*
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing **Step 1** above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in February 2007.

Ohio EPA is an Equal Opportunity Employer

If you have any questions, please contact me at (330) 963-1194.

Sincerely,

Beth R Madis

Beth R. Madis
Environmental Specialist
Division of Drinking and Ground Waters

BRM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW
Wayne County Health Department
Nancy Glenny, Ohio EPA, NEDO, DDAGW