



State of Ohio Environ  
Northeast

OH8560712 BROOKLYN'S PIZZERIA TOO PWS

22 03/12/07



2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200  
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 12, 2007

RE: WAYNE COUNTY  
WESTWOOD CENTRE PWS  
TRANSIENT NON-COMMUNITY  
PWS # 8560712

Westwood Centre  
1638 Old Columbus Rd.  
Wooster, OH 44691

**Subject: Notice of Violation of Monthly Maximum Contaminant Level  
for Total Coliform Bacteria**

Dear Sir or Madam:

Your public water system incurred a **monthly** violation of rule 3745-81-14 of the Ohio Administrative Code (OAC) in March 2007.

A monthly violation of rule 3745-81-14 occurs when more than one or greater than five percent of your samples within the month were total coliform-positive.

<b>Actions required as a result of the above violation</b>	
Step 1	<p><b>Within 30 days</b> issue the attached public notice of the violation in accordance with rule 3745-81-32 of the Ohio Administrative Code by the following method(s) to reach all persons served by the public water system:</p> <ol style="list-style-type: none"> <li>Posting in conspicuous locations (restrooms, drinking fountains, vending areas, restaurants, bulletin boards, etc.)</li> </ol> <p><i>The language in italic on the attached public notice is mandatory language and must be included as written.</i></p>
Step 2	Immediately initiate an investigation to determine and eliminate the cause and extent of bacterial contamination.
Step 3	Within ten (10) days of completing <b>Step 1</b> above, fill out the attached verification form and send along with a copy of the public notification issued to the District Office of the Ohio EPA.
Step 4	Because you are required to monitor with at least five (5) samples in the next month following any total coliform-positive result, you must take at least five (5) total coliform samples in April 2007.

WESTWOOD CENTRE PWS  
MARCH 12, 2007  
PAGE 2

If you have any questions, please contact me at (330) 963-1194.

Sincerely,

A handwritten signature in cursive script that reads "Beth R. Madis".

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

enclosures

cc: Toni Buchanan, Ohio EPA, Central Office, DDAGW  
Wayne County Health Department  
Kim Etters, Ohio EPA, NEDO, DDAGW