



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Hillig, Director

May 7, 2012

RE: **NOTICE OF VIOLATION**
MAHONING COUNTY
SOUTH RANGE LOCAL SCHOOLS K-12
NON-TRANSIENT PUBLIC WATER SYSTEM
PWS ID #OH5054712

CERTIFIED MAIL 70042510000240751848

Mr. Dennis Dunham
South Range Local Schools
11822 South Avenue
North Lima, OH 44452

Dear Mr. Dunham:

This letter is notification that the South Range Local Schools K-12 Public Water System (PWS) is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points in the distribution system.

This violation of the OAC is based upon information submitted by the South Range Local Schools K-12 PWS as reported on Monthly Operating Report (MOR) #5002 for the month of **April 2012**. Below is a table which indicates the reporting months and the number of days when the free chlorine residual was less than 0.2 mg/L or was not recorded.

Reporting Month	Number of days the free chlorine residual < 0.2 mg/L
April 2012	9

The evaluation/investigation and corrective actions described in your May 2, 2012 response to the previous April 26, 2012 low free chlorine residual notice of violation should continue until this issue is resolved, and free chlorine residuals in the distribution system are maintained above 0.2 mg/L. Please provide a written explanation updating the status of your corrective actions within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1182.

Respectfully,

Chris Maslo
Environmental Specialist
Division of Drinking and Ground Waters

CM:ds

cc: Firl Byers, Certified Operator

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov