



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**



May 4, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Re: Wood County  
NWWSD-Bairdstown  
Community Water System  
PWS ID# 8703903

Mr. Jerry Greiner, Executive Director  
Northwestern Water & Sewer District  
12560 Middleton Pike  
P.O. Box 348  
Bowling Green, Ohio 43402

The March 2012 Drinking Water Operation Report (EPA 5002) for Northwestern Water and Sewer District-Bairdstown has been reviewed and is in violation the Ohio Administrative Code (OAC) Rule 3745-83-01.

OAC Rule 3745-83-01(C)(1) requires all community public water systems to maintain a minimum chlorine residual of at least two-tenths milligram per liter free chlorine or one milligram per liter combined chlorine measured at representative points throughout the distribution system at least once daily.

A review of March 2012 report shows five days during the month, a chlorine residual was not being maintained in the distribution system. Take steps immediately to correct this problem.

If you have any questions, contact me at (419) 373-3089 or via email at [jill.schiefer@epa.state.oh.us](mailto:jill.schiefer@epa.state.oh.us).

Sincerely,

Jill A. Schiefer  
Environmental Specialist  
Division of Drinking and Ground Waters

/cg

pc: Wood County Health Department  
DDAGW, NWDO File

