



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 21, 2011

Re: Garden Acres Water Company
Clark County
Community Water System
PWS ID: 1202412

Mr. Mark Rucker
President
241 Larchmont Road
Springfield, Ohio 45503

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Rucker:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report shall contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **May 2011**, Garden Acres Water Company public water system did not send the monthly report to this office. However, on May 22, 2011 and May 23, 2011, the free and total chlorine residual is reported at zero. This is a violation of the rule. All community water systems that use chlorine disinfection shall carry a free chlorine residual of at least 0.2 mg/L OR a combine chlorine residual of 1.0 mg/L. Garden Acres Water Company shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month with the required data.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden

Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Bornino, Ohio EPA, DDAGW, CO
Tom Fyffe, Operator
ec: Clark County Health Department

TD\bp