Ohio | Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 10, 2011

Re: **Stateline Agri, Inc.**
Darke County
Community Water System
PWS ID: 1901012

Stateline Agri, Inc.
Attn: Kyle Stegall
9159 State Route 118
Ansonia, OH 45303

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Stegall:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of **December 2010**, Stateline Agri, Inc. public water system failed to send the monthly report to this office. This is a violation of the rule. Stateline Agri, Inc. public water system shall provide an explanation in writing to Ohio EPA concerning this matter; and explain what steps will be taken to ensure that future reports are submitted no later than the tenth of the month following the month for which the report was prepared.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6118.

Sincerely,

Gina Hayes
Division of Drinking and Ground Waters
Public Drinking Water Unit

GH/rb

CC: Dave Bornino, Ohio EPA, DDAGW, CO
Darke County Health Department

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov