



State of Ohio Environment

401 East Fifth Street
Dayton, Ohio 45402-2911

Southwest
TELE: (937)285-6357 F.
www.epa.state.oh.us

Lee Fisher, Lieutenant Governor
Chris Korleski, Director

March 3, 2009

Re: Valley View MHP
Champaign County
Community Water System
PWS ID: 1101312

Valley View MHP LKL LTD
Attn: William Neer
P.O. Box 790
Urbana, OH 43078

Subject: Monthly Operating Report, Failure to Submit

Dear Mr. Neer:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. During the entire year of 2008, there were no monthly operating reports sent to this office. For the month of January 2009, Valley View MHP public water system also failed to send the monthly report to this office. This is a violation of the rule. Valley View MHP public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden

Division of Drinking and Groundwaters
Public Drinking Water Unit

cc: Dave Evans, Ohio EPA, DDAGW, CO
Champaign County Health Department
File

TD/mab