



State of Ohio Environmenta

Southwest Dist

401 E. Fifth St.
Dayton, Ohio 45402

TELE: (937) 285-6357 FAX:
www.epa.state

Chris Korleski, Director

July 31, 2009

Re: Valley View MHP
Champaign County
Community Water System
PWS ID: 1101312

William Neer
Valley View MHP LKL LTD
P.O. Box 790
Urbana, Ohio 43078

Subject: Monthly Operating Report,

Dear Mr. Neer:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of June 2009, Valley View MHP public water system did send in a monthly report to this office. However, there were only six days of free and total chlorine residual recorded. This is a violation of the rule. Valley View MHP public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at (937) 285-6085.

Sincerely,

Tya Darden
Division of Drinking and Groundwaters
Public Drinking Water Unit

CC: DDAGW/ CO
Brad Hudson
File
EC: Champaign County Health Department

TD/plh