



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

June 21, 2011

Re: Valley View MHP  
Champaign County  
Community Water System  
PWS ID: OH1101312

Valley View MHP LKL LTD  
Attention: William Neer  
P.O. Box 790  
Urbana, Ohio 43078

**Subject: Monthly Operating Report, Violation**

Dear Mr. Neer:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of May 2011, Valley View MHP public water system did send in a monthly report to this office. However, there were at least four days where the free and total chlorine residual was not recorded. This is a violation of the rule. Valley View MHP public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,

Tya Darden  
Division of Drinking and Groundwaters  
Public Drinking Water Unit

cc: Dave Evans, Ohio EPA, DDAGW, CO  
Brad Hudson  
**File**

ec: Champaign County Health Department

TD\bp