

**Environmental  
Protection Agency**

Lee Stedman, Governor  
Lee Fisher, Lt. Governor  
Chris Korfusik, Director

October 22, 2010

Re: **Valley View MHP**  
**Champaign County**  
**Community Water System**  
**PWS ID: 1101312**

Valley View MHP LKL LTD  
Attn: William Neer  
P.O. Box 790  
Urbana, OH 43078

**Subject: Monthly Operating Report, Violation**

Dear Mr. Neer:

According to OAC-3745-83-01 Operational Requirements, each community public water system shall prepare an operation report for each month of operation. This report should contain the free and total chlorine daily residuals in the distribution and at the plant tap. For the month of September 2010, Valley View MHP public water system did send in a monthly report to this office. However, there were seven days of missing data for free and total chlorine residual recorded. This is a violation of the rule. Valley View MHP public water system shall provide an explanation in writing to Ohio EPA concerning this matter and explain what steps will be taken to ensure that future reports are submitted each month.

If you have any further questions or comments concerning your water system, please feel free to contact me at 937-285-6085.

Sincerely,



Tya Darden  
Division of Drinking and Groundwaters  
Public Drinking Water Unit

TD/ka

cc: Dave Evans, Ohio EPA, DDAGW, CO  
Champaign County Health Department  
Brad Hudson, PO Box 62, West Liberty, OH 43357  
File